

NOTICE: Tanks are Ineligible to Receive Fuel Deliveries in Accordance with Nevada Administrative Code 459.9941 – Effective 05/10/2023

Facility: City Gas & Liquor, 240 W Winnemucca Blvd, Winnemucca, NV 89445
Facility ID #: 5-000002

The subject facility has received this notice in accordance with Nevada Administrative Code (NAC) 459.9942. The Nevada Division of Environmental Protection (NDEP) is required (NAC 459.9941) to red tag a tank system that has not installed equipment designed to perform the following functions: Prevent a spill or overflow, detect a leak, or protect the underground storage tank (UST) from corrosion. NDEP also has authority to apply a red tag to any tank system where the equipment described above is found to be nonoperational and has not been corrected. **Refer to the enclosed notice of violation letter for specific noncompliance issues identified at the subject facility.**

A red tag shall be applied to each noncompliant tank listed below no later 05/10/2023:

Tank ID #	Tank Capacity	Product Type Stored (i.e. Regular, Premium, Red Diesel, etc.)	Tank Location Description (See note below)
1	6,000-gal	Gasoline	North Side of Building
2	4,000-gal	Gasoline	North Side of Building
3	4,000-gal	Gasoline	North Side of Building
4	6,000-gal	Gasoline	North Side of Building

Note: If a tank location description is not provided, the tank is located within a single group of tanks (tank pad) at the subject facility. The above description is intended to be used when multiple tank pads are present at a facility or there is more than one tank with the same capacity and similar products (e.g. Two 10,000 gallon tanks with regular unleaded gasoline adjacent to each other could be distinguished using an East/West, Center, or North/South description).

A red tag shall be applied to the above listed tank(s) in the following manner:

- 1) A red canvas bag with the words “NO FUEL DELIVERY” shall be placed over the tank’s delivery fill pipe. These words shall be visible to the delivery operator.
- 2) A blue strap stamped with “SEALED DO NOT REMOVE” shall be wrapped around the base of the red canvas bag and cinched in place around the tank’s fill pipe riser. The strap must be placed tight enough around the fill pipe riser to prevent unintended removal of the red canvas bag.
- 3) A red tag shall be affixed to the red canvas bag using the white strap placed through the grommet at the top of the red canvas bag.

Altering or removal of the equipment listed above may result in civil penalties up to \$5,000 per day.

The above listed red tag(s) shall be removed from the affected tank system(s) in accordance with NAC 459.9944 pursuant to an owner or operator providing NDEP documentation indicating the noncompliance issues have been addressed. A list of necessary corrective action(s) has been provided within the accompanying notice of violation letter or inspection form.